

# DRIFTSRAPPORT

Månedsrapport September 2018

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	1879,38 m <sup>3</sup>
Boring_1	1002,07 m <sup>3</sup>
Boring_2	877,31 m <sup>3</sup>
TOTAL UDPUMPET	1828,95 m <sup>3</sup>
Udpumpning	1828,95 m <sup>3</sup>
TOTAL SKYLLEVAND	0,04 m <sup>3</sup>
Skyllevand	0,04 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	2286 kWh
Delproces / udpumpning	836 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	5 skyl
Filter 2	4 skyl
Filter 3	8 skyl
Filter 4	8 skyl

## DRIFTTIMER



BORINGER	
1	109 timer
2	125 timer
PUMPER	
1	381 timer
2	364 timer
FILTERMOTOR	
1	234 timer
2	1 timer

# DRIFTSRAPPORT

Månedssrapport September 2018

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,29 m	-54,16 m	4,87 m	1002,07 m <sup>3</sup>
2	-49,48 m	-53,46 m	3,98 m	877,31 m <sup>3</sup>

Fordeling for indvundet vand



● Boring\_1 : 53.3%  
● Boring\_2 : 46.7%



Blue Control®  
BC7000