

DRIFTSRAPPORT

Månedssrapport August 2022

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2502,68 m ³
Boring 1	1243,51 m ³
Boring 2	1259,17 m ³
TOTAL UDPUMPET	2479,04 m ³
Udpumpning	2479,04 m ³
TOTAL SKYLLEVAND	8,16 m ³
Skyllevand	8,16 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2410 kWh
Delproces / udpumpning	892 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	6 skyl
Filter 2	6 skyl
Filter 3	9 skyl
Filter 4	9 skyl

DRIFTTIMER



BORINGER	
1	150 timer
2	151 timer
PUMPER	
1	364 timer
2	380 timer
FILTERMOTOR	
1	302 timer
2	1 timer



Blue Control®
BC7000



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,55 m	-53,88 m	4,33 m	1243,51 m ³
2	-49,48 m	-53,92 m	4,44 m	1259,17 m ³

Fordeling for indvundet vand

