

DRIFTSRAPPORT

Månedssrapport August 2018

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	1264,25 m ³
Boring_1	654,65 m ³
Boring_2	609,60 m ³
TOTAL UDPUMPET	2461,40 m ³
Udpumpning	2461,40 m ³
TOTAL SKYLLEVAND	16,00 m ³
Skyllevand	16,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2695 kWh
Delproces / udpumpning	939 kWh



NATFORBRUG

Gennemsnitligt vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	6 skyl
Filter 2	6 skyl
Filter 3	8 skyl
Filter 4	8 skyl

DRIFTTIMER



BORINGER	
1	141 timer
2	171 timer
PUMPER	
1	364 timer
2	380 timer
FILTERMOTOR	
1	311 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport August 2018

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	0,00 m	-54,10 m	54,10 m	654,65 m ³
2	0,00 m	-53,40 m	53,40 m	609,60 m ³

Fordeling for indvundet vand



Blue Control®
BC7000