

DRIFTSRAPPORT

Månedssrapport Januar 2022

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2129,82 m ³
Boring 1	1054,94 m ³
Boring 2	1074,88 m ³
TOTAL UDPUMPET	2099,65 m ³
Udpumpning	2099,65 m ³
TOTAL SKYLLEVAND	2,18 m ³
Skyllevand	2,18 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2537 kWh
Delproces / udpumpning	913 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

DRIFTTIMER



BORINGER	
1	156 timer
2	155 timer
PUMPER	
1	380 timer
2	364 timer
FILTERMOTOR	
1	309 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport Januar 2022

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,98 m	-52,73 m	3,75 m	1054,94 m ³
2	-49,32 m	-53,37 m	4,05 m	1074,88 m ³

Fordeling for indvundet vand



● Boring 1 : 49.5%
● Boring 2 : 50.5%



Blue Control®
BC7000