

# DRIFTSRAPPORT

Månedssrapport August 2020

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2565,85 m <sup>3</sup>
Boring 1	1279,16 m <sup>3</sup>
Boring 2	1286,69 m <sup>3</sup>
TOTAL UDPUMPET	2523,55 m <sup>3</sup>
Udpumpning	2523,55 m <sup>3</sup>
TOTAL SKYLLEVAND	0,00 m <sup>3</sup>
Skyllevand	0,00 m <sup>3</sup>

## ELFORBRUG



ELFORBRUG	
Samlet proces	2906 kWh
Delproces / udpumpning	961 kWh



## NATFORBRUG



## FILTRE

Filter 1	6 skyl
Filter 2	6 skyl
Filter 3	9 skyl
Filter 4	9 skyl

## DRIFTTIMER



BORINGER	
1	163 timer
2	159 timer
PUMPER	
1	364 timer
2	380 timer
FILTERMOTOR	
1	322 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedsrapport August 2020

Faurbo Vandværk

2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,06 m	-53,50 m	4,44 m	1279,16 m <sup>3</sup>
2	-49,31 m	-53,74 m	4,43 m	1286,69 m <sup>3</sup>



Blue Control®  
BC7000