

# DRIFTSRAPPORT

Månedsrapport December 2020

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	1994,08 m <sup>3</sup>
Boring 1	995,99 m <sup>3</sup>
Boring 2	998,09 m <sup>3</sup>
TOTAL UDPUMPET	1961,10 m <sup>3</sup>
Udpumpning	1961,10 m <sup>3</sup>
TOTAL SKYLLEVAND	0,00 m <sup>3</sup>
Skyllevand	0,00 m <sup>3</sup>

## ELFORBRUG



ELFORBRUG	
Samlet proces	2196 kWh
Delproces / udpumpning	869 kWh



## NATFORBRUG



## FILTRE

Filter 1	4 skyl
Filter 2	4 skyl
Filter 3	7 skyl
Filter 4	7 skyl

## DRIFTTIMER



BORINGER	
1	133 timer
2	130 timer
PUMPER	
1	364 timer
2	380 timer
FILTERMOTOR	
1	263 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedssrapport December 2020

Faurbo Vandværk

2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,99 m	-53,09 m	4,10 m	995,99 m <sup>3</sup>
2	-49,22 m	-53,52 m	4,29 m	998,09 m <sup>3</sup>



Blue Control®  
BC7000