

DRIFTSRAPPORT

Månedsrapport Februar 2019

Faurbo Vandværk

1/2



MÆNGDER

| | |
|------------------|------------------------|
| TOTAL INDVUNDET | 1768,01 m ³ |
| Boring 1 | 931,16 m ³ |
| Boring 2 | 836,85 m ³ |
| TOTAL UDPUMPET | 1650,06 m ³ |
| Udpumpning | 1650,06 m ³ |
| TOTAL SKYLLEVAND | 0,00 m ³ |
| Skyllevand | 0,00 m ³ |

ELFORBRUG




| | |
|------------------------|----------|
| ELFORBRUG | |
| Samlet proces | 2192 kWh |
| Delproces / udpumpning | 755 kWh |



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

| | |
|----------|--------|
| Filter 1 | 4 skyl |
| Filter 2 | 4 skyl |
| Filter 3 | 6 skyl |
| Filter 4 | 6 skyl |

DRIFTTIMER



| | |
|-------------|-----------|
| BORINGER | |
| 1 | 103 timer |
| 2 | 131 timer |
| PUMPER | |
| 1 | 336 timer |
| 2 | 336 timer |
| FILTERMOTOR | |
| 1 | 234 timer |
| 2 | 1 timer |



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Februar 2019

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

| BORING | HØJEST | LAVEST | SÆNKNING | MÆNGDE |
|--------|----------|----------|----------|-----------------------|
| 1 | -49,12 m | -53,97 m | 4,85 m | 931,16 m ³ |
| 2 | -49,37 m | -53,20 m | 3,84 m | 836,85 m ³ |

Fordeling for indvundet vand



Blue Control®
BC7000