

DRIFTSRAPPORT

Månedsrapport Januar 2020

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	1875,94 m ³
Boring 1	950,43 m ³
Boring 2	925,51 m ³
TOTAL UDPUMPET	1842,67 m ³
Udpumpning	1842,67 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2179 kWh
Delproces / udpumpning	840 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	4 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER	
1	110 timer
2	110 timer
PUMPER	
1	384 timer
2	360 timer
FILTERMOTOR	
1	220 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport Januar 2020

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,75 m	-53,36 m	4,61 m	950,43 m ³
2	-48,96 m	-53,76 m	4,80 m	925,51 m ³

Fordeling for indvundet vand



Blue Control®
BC7000