

# DRIFTSRAPPORT

Månedssrapport Februar 2020

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	1741,15 m <sup>3</sup>
Boring 1	873,53 m <sup>3</sup>
Boring 2	867,62 m <sup>3</sup>
TOTAL UDPUMPET	1710,40 m <sup>3</sup>
Udpumpning	1710,40 m <sup>3</sup>
TOTAL SKYLLEVAND	0,00 m <sup>3</sup>
Skyllevand	0,00 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	2031 kWh
Delproces / udpumpning	784 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	4 skyl
Filter 2	4 skyl
Filter 3	6 skyl
Filter 4	6 skyl

## DRIFTTIMER



BORINGER	
1	102 timer
2	105 timer
PUMPER	
1	360 timer
2	336 timer
FILTERMOTOR	
1	206 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedsrapport Februar 2020

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,46 m	-53,16 m	4,70 m	873,53 m <sup>3</sup>
2	-48,65 m	-53,39 m	4,74 m	867,62 m <sup>3</sup>

Fordeling for indvundet vand



- Boring 1 : 50.2%
- Boring 2 : 49.8%



Blue Control®  
BC7000