


# Faurbo Vandværk

## Årsrapport 2017



## Mængder

Udpumpet vandmængde:	Total: 22.762,5 m <sup>3</sup>	Måler 1: 22.762,5 m <sup>3</sup>
Indvundet vandmængde:	Total: 22.368,2 m <sup>3</sup>	Måler 2: 22.368,2 m <sup>3</sup>

## Forbrug

Elforbrug:	Total: -25.612,1 kWh	Udpumpet: 9.652,8 kWh
	Total: -1,13 kWh/m <sup>3</sup>	Udpumpet: 0,42 kWh/m <sup>3</sup>

## Flow

### Flow måler 1:

Min. Flow:	0,00 m <sup>3</sup> /h	Tidspunkt: 03-01-17 00:05:21
Max. Flow:	18,36 m <sup>3</sup> /h	Tidspunkt: 31-05-17 19:11:12

### Flow måler 2:

Min. Flow:	0,00 m <sup>3</sup> /h	Tidspunkt: 17-01-18 01:34:28
Max. Flow:	24,27 m <sup>3</sup> /h	Tidspunkt: 27-03-17 14:14:50

## Niveauer i boringer:

Boring 1 niveau:	Højest: 0,00 m	Lavest: -52,78 m	Sænkning: 52,78 m
Boring 2 niveau:	Højest: 0,00 m	Lavest: -54,15 m	Sænkning: 54,15 m

## Filter:

Filter 1:	Antal skyl:	61
Filter 2:	Antal skyl:	65
Filter 3:	Antal skyl:	61
Filter 4:	Antal skyl:	61

## Drifttimer:

	Periode:	Total:
Boring 1:	1262 Timer	3902 Timer
Boring 2:	2122 Timer	6703 Timer
Pumpe 1:	4190 Timer	14479 Timer
Pumpe 2:	4200 Timer	14478 Timer