


# Faurbo Vandværk

## Månedssrapport 11-2017



## Mængder

Udpumpet vandmængde:	Total:	1.721,3 m <sup>3</sup>	Måler 1:	1.721,3 m <sup>3</sup>
Indvundet vandmængde:	Total:	1.756,3 m <sup>3</sup>	Måler 2:	1.756,3 m <sup>3</sup>

## Forbrug

Elforbrug:	Total:	1.769,2 kWh	Udpumpet:	774,9 kWh
	Total:	1,03 kWh/m <sup>3</sup>	Udpumpet:	0,45 kWh/m <sup>3</sup>

## Flow

### Flow måler 1:

Min. Flow:	0,00 m <sup>3</sup> /h	Tidspunkt: 01-11-17 00:01:02
Max. Flow:	13,97 m <sup>3</sup> /h	Tidspunkt: 29-11-17 03:09:40

### Flow måler 2:

Min. Flow:	0,00 m <sup>3</sup> /h	Tidspunkt: 01-11-17 00:00:00
Max. Flow:	15,92 m <sup>3</sup> /h	Tidspunkt: 24-11-17 09:18:28

## Niveauer i boringer:

Boring 1 niveau:	Højest:	-48,34 m	Lavest:	-52,53 m	Sænkning:	4,19 m
Boring 2 niveau:	Højest:	-48,90 m	Lavest:	-53,82 m	Sænkning:	4,91 m

## Filter:

Filter 1:	Antal skyl:	5
Filter 2:	Antal skyl:	5
Filter 3:	Antal skyl:	11
Filter 4:	Antal skyl:	11

## Drifttimer:

	Periode:	Total:
Boring 1:	90 Timer	3820 Timer
Boring 2:	132 Timer	6585 Timer
Pumpe 1:	343 Timer	14156 Timer
Pumpe 2:	343 Timer	14173 Timer