


# Faurbo Vandværk

## Månedssrapport 04-2015



## Mængder

Udpumpet vandmængde:	Total:	1.490,4 m <sup>3</sup>	Måler 1:	1.490,4 m <sup>3</sup>
Indvundet vandmængde:	Total:	1.475,9 m <sup>3</sup>	Måler 2:	1.475,9 m <sup>3</sup>

## Forbrug

Elforbrug:	Total:	-10.223,9 kWh	Udpumpet:	925,6 kWh
	Total:	-6,86 kWh/m <sup>3</sup>	Udpumpet:	0,62 kWh/m <sup>3</sup>

## Flow

### Flow måler 1:

Min. Flow:	0,00 m <sup>3</sup> /h	Tidspunkt: 01-04-15 00:06:56
Max. Flow:	14,95 m <sup>3</sup> /h	Tidspunkt: 10-04-15 05:02:20

### Flow måler 2:

Min. Flow:	0,00 m <sup>3</sup> /h	Tidspunkt: 01-04-15 00:00:00
Max. Flow:	13,20 m <sup>3</sup> /h	Tidspunkt: 08-04-15 13:30:27

## Niveauer i boringer:

Boring 1 niveau:	Højest:	0,00 m	Lavest:	-51,79 m	Sænkning:	51,79 m
Boring 2 niveau:	Højest:	0,00 m	Lavest:	-53,41 m	Sænkning:	53,41 m

## Filter:

Filter 1:	Antal skyl:	4
Filter 2:	Antal skyl:	4

## Drifttimer:

	Periode:	Total:
Boring 1:	84 Timer	582 Timer
Boring 2:	132 Timer	873 Timer
Pumpe 1:	365 Timer	2478 Timer
Pumpe 2:	353 Timer	2497 Timer