

DRIFTSRAPPORT

Månedssrapport Januar 2021

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2024,12 m ³
Boring 1	1002,64 m ³
Boring 2	1021,48 m ³
TOTAL UDPUMPET	1991,23 m ³
Udpumpning	1991,23 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG



ELFORBRUG	
Samlet proces	2235 kWh
Delproces / udpumpning	877 kWh



NATFORBRUG



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER	
1	136 timer
2	135 timer
PUMPER	
1	380 timer
2	364 timer
FILTERMOTOR	
1	270 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Januar 2021

Faurbo Vandværk

2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,79 m	-53,25 m	4,46 m	1002,64 m ³
2	-49,04 m	-53,40 m	4,37 m	1021,48 m ³



Blue Control®
BC7000