

# DRIFTSRAPPORT

Måned rapport Maj 2022

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2006,49 m <sup>3</sup>
Boring 1	997,91 m <sup>3</sup>
Boring 2	1008,58 m <sup>3</sup>
TOTAL UDPUMPET	1949,66 m <sup>3</sup>
Udpumpning	1949,66 m <sup>3</sup>
TOTAL SKYLLEVAND	5,55 m <sup>3</sup>
Skyllevand	5,55 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	1940 kWh
Delproces / udpumpning	767 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	4 skyl
Filter 2	4 skyl
Filter 3	7 skyl
Filter 4	7 skyl

## DRIFTTIMER



BORINGER	
1	118 timer
2	118 timer
PUMPER	
1	351 timer
2	332 timer
FILTERMOTOR	
1	235 timer
2	1 timer



Blue Control®  
BC7000



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,89 m	-53,43 m	4,54 m	997,91 m <sup>3</sup>
2	-49,03 m	-53,78 m	4,76 m	1008,58 m <sup>3</sup>

Fordeling for indvundet vand

