


Faurbo Vandværk

Månedsrapport 09-2017



Mængder

Udpumpet vandmængde:	Total:	2.056,3 m ³	Måler 1:	2.056,3 m ³
Indvundet vandmængde:	Total:	2.097,8 m ³	Måler 2:	2.097,8 m ³

Forbrug

Elforbrug:	Total:	2.105,5 kWh	Udpumpet:	847,9 kWh
	Total:	1,02 kWh/m ³	Udpumpet:	0,41 kWh/m ³

Flow

Flow måler 1:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 01-09-17 00:00:00
Max. Flow:	13,55 m ³ /h	Tidspunkt: 09-09-17 03:09:35

Flow måler 2:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 01-09-17 00:00:00
Max. Flow:	14,26 m ³ /h	Tidspunkt: 23-09-17 17:00:24

Niveauer i boringer:

Boring 1 niveau:	Højest:	-48,52 m	Lavest:	-52,76 m	Sænkning:	4,23 m
Boring 2 niveau:	Højest:	-49,09 m	Lavest:	-54,15 m	Sænkning:	5,06 m

Filter:

Filter 1:	Antal skyl:	5
Filter 2:	Antal skyl:	5
Filter 3:	Antal skyl:	11
Filter 4:	Antal skyl:	11

Drifttimer:

	Periode:	Total:
Boring 1:	111 Timer	3630 Timer
Boring 2:	153 Timer	6305 Timer
Pumpe 1:	356 Timer	13459 Timer
Pumpe 2:	349 Timer	13461 Timer