

DRIFTSRAPPORT

Månedsrapport Juli 2022

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2546,31 m ³
Boring 1	1281,34 m ³
Boring 2	1264,97 m ³
TOTAL UDPUMPET	2523,51 m ³
Udpumpning	2523,51 m ³
TOTAL SKYLLEVAND	7,05 m ³
Skyllevand	7,05 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2393 kWh
Delproces / udpumpning	901 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

DRIFTTIMER



BORINGER	
1	153 timer
2	150 timer
PUMPER	
1	380 timer
2	364 timer
FILTERMOTOR	
1	303 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Juli 2022

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,21 m	-53,85 m	4,64 m	1281,34 m ³
2	-49,35 m	-53,84 m	4,49 m	1264,97 m ³

Fordeling for indvundet vand



Blue Control®
BC7000