


Faurbo Vandværk

Månedssrapport 03-2015



Mængder

Udpumpet vandmængde:	Total:	1.041,7 m ³	Måler 1:	1.041,7 m ³
Indvundet vandmængde:	Total:	1.560,3 m ³	Måler 2:	1.560,3 m ³

Forbrug

Elforbrug:	Total:	2.051,7 kWh	Udpumpet:	1.046,5 kWh
	Total:	1,97 kWh/m ³	Udpumpet:	1,00 kWh/m ³

Flow

Flow måler 1:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 01-03-15 00:00:00
Max. Flow:	8,20 m ³ /h	Tidspunkt: 12-03-15 03:11:25

Flow måler 2:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 01-03-15 00:00:00
Max. Flow:	8,24 m ³ /h	Tidspunkt: 23-03-15 16:00:30

Niveauer i boringer:

Boring 1 niveau:	Højest:	-47,82 m	Lavest:	-51,89 m	Sænkning:	4,07 m
Boring 2 niveau:	Højest:	-48,37 m	Lavest:	-53,45 m	Sænkning:	5,07 m

Filter:

Filter 1:	Antal skyl:	2
Filter 2:	Antal skyl:	3

Drifttimer:

	Periode:	Total:
Boring 1:	93 Timer	498 Timer
Boring 2:	134 Timer	741 Timer
	0 Timer	1 Timer
Pumpe 1:	370 Timer	2113 Timer
Pumpe 2:	397 Timer	2144 Timer