

DRIFTSRAPPORT

Månedsrapport Marts 2024

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2279,24 m ³
Boring 1	1142,39 m ³
Boring 2	1136,85 m ³
TOTAL UDPUMPET	2262,34 m ³
Udpumpning	2262,34 m ³
TOTAL SKYLLEVAND	3,11 m ³
Skyllevand	3,11 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2502 kWh
Delproces / udpumpning	857 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

DRIFTTIMER



BORINGER	
1	154 timer
2	153 timer
PUMPER	
1	363 timer
2	380 timer
FILTERMOTOR	
1	307 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Marts 2024

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,30 m	-52,50 m	4,19 m	1142,39 m ³
2	-48,53 m	-52,61 m	4,08 m	1136,85 m ³

Fordeling for indvundet vand



● Boring 1 : 50.1%
● Boring 2 : 49.9%



Blue Control®
BC7000