

DRIFTSRAPPORT

Månedsrapport Juni 2019

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2289,44 m ³
Boring 1	1202,78 m ³
Boring 2	1086,66 m ³
TOTAL UDPUMPET	2267,65 m ³
Udpumpning	2267,65 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2440 kWh
Delproces / udpumpning	892 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

DRIFTTIMER



BORINGER	
1	136 timer
2	167 timer
PUMPER	
1	356 timer
2	364 timer
FILTERMOTOR	
1	302 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Juni 2019

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,02 m	-53,73 m	4,71 m	1202,78 m ³
2	-49,27 m	-52,87 m	3,60 m	1086,66 m ³

Fordeling for indvundet vand



● Boring 1 : 52.5%
● Boring 2 : 47.5%



Blue Control®
BC7000