


Faurbo Vandværk

Månedsrapport 10-2017



Mængder

Udpumpet vandmængde:	Total:	1.941,3 m ³	Måler 1:	1.941,3 m ³
Indvundet vandmængde:	Total:	1.973,8 m ³	Måler 2:	1.973,8 m ³

Forbrug

Elforbrug:	Total:	1.950,3 kWh	Udpumpet:	837,5 kWh
	Total:	1,00 kWh/m ³	Udpumpet:	0,43 kWh/m ³

Flow

Flow måler 1:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 01-10-17 00:02:38
Max. Flow:	15,32 m ³ /h	Tidspunkt: 26-10-17 14:17:46

Flow måler 2:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 01-10-17 00:00:00
Max. Flow:	10,67 m ³ /h	Tidspunkt: 04-10-17 15:20:28

Niveauer i boringer:

Boring 1 niveau:	Højest:	-48,33 m	Lavest:	-52,63 m	Sænkning:	4,30 m
Boring 2 niveau:	Højest:	-48,90 m	Lavest:	-53,89 m	Sænkning:	4,99 m

Filter:

Filter 1:	Antal skyl:	5
Filter 2:	Antal skyl:	5
Filter 3:	Antal skyl:	10
Filter 4:	Antal skyl:	10

Drifttimer:

	Periode:	Total:
Boring 1:	100 Timer	3730 Timer
Boring 2:	148 Timer	6453 Timer
Pumpe 1:	354 Timer	13813 Timer
Pumpe 2:	369 Timer	13830 Timer