

# DRIFTSRAPPORT

Månedsrapport September 2019

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2097,93 m <sup>3</sup>
Boring 1	1094,23 m <sup>3</sup>
Boring 2	1003,70 m <sup>3</sup>
TOTAL UDPUMPET	2078,13 m <sup>3</sup>
Udpumpning	2078,13 m <sup>3</sup>
TOTAL SKYLLEVAND	0,00 m <sup>3</sup>
Skyllevand	0,00 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	2369 kWh
Delproces / udpumpning	859 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	7 skyl
Filter 4	7 skyl

## DRIFTTIMER



BORINGER	
1	125 timer
2	157 timer
PUMPER	
1	347 timer
2	373 timer
FILTERMOTOR	
1	282 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedsrapport September 2019

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,37 m	-53,96 m	4,60 m	1094,23 m <sup>3</sup>
2	-49,71 m	-53,33 m	3,62 m	1003,70 m <sup>3</sup>

Fordeling for indvundet vand



Blue Control®  
BC7000