

DRIFTSRAPPORT

Årsrapport 2018

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	9011,76 m ³
Boring 1	4782,91 m ³
Boring 2	4228,85 m ³
TOTAL UDPUMPET	16629,80 m ³
Udpumpning	16629,80 m ³
TOTAL SKYLLEVAND	6902,04 m ³
Skyllevand	6902,04 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	18971 kWh
Delproces / udpumpning	6726 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	40 skyl
Filter 2	40 skyl
Filter 3	73 skyl
Filter 4	73 skyl

DRIFTTIMER



BORINGER	
1	978 timer
2	1145 timer
PUMPER	
1	2753 timer
2	2745 timer
FILTERMOTOR	
1	2115 timer
2	5 timer



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	0,00 m	-54,24 m	54,24 m	4782,91 m ³
2	0,00 m	-53,46 m	53,46 m	4228,85 m ³

Fordeling for indvundet vand

