

DRIFTSRAPPORT

Månedsrapport December 2023

Faurbo Vandværk

1/2



MÆNGDER

| | |
|------------------|------------------------|
| TOTAL INDVUNDET | 2244,09 m ³ |
| Boring 1 | 1126,97 m ³ |
| Boring 2 | 1117,12 m ³ |
| TOTAL UDPUMPET | 2227,80 m ³ |
| Udpumpning | 2227,80 m ³ |
| TOTAL SKYLLEVAND | 6,44 m ³ |
| Skyllevand | 6,44 m ³ |

ELFORBRUG




| | |
|------------------------|----------|
| ELFORBRUG | |
| Samlet proces | 2494 kWh |
| Delproces / udpumpning | 852 kWh |



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

| | |
|----------|--------|
| Filter 1 | 5 skyl |
| Filter 2 | 5 skyl |
| Filter 3 | 8 skyl |
| Filter 4 | 8 skyl |

DRIFTTIMER



| | |
|-------------|-----------|
| BORINGER | |
| 1 | 144 timer |
| 2 | 142 timer |
| PUMPER | |
| 1 | 380 timer |
| 2 | 364 timer |
| FILTERMOTOR | |
| 1 | 286 timer |
| 2 | 1 timer |



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport December 2023

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

| BORING | HØJEST | LAVEST | SÆNKNING | MÆNGDE |
|--------|----------|----------|----------|------------------------|
| 1 | -48,90 m | -53,13 m | 4,23 m | 1126,97 m ³ |
| 2 | -48,81 m | -53,23 m | 4,42 m | 1117,12 m ³ |

Fordeling for indvundet vand



● Boring 1 : 50.2%
● Boring 2 : 49.8%



Blue Control®
BC7000