

DRIFTSRAPPORT

Månedssrapport November 2020

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	1984,57 m ³
Boring 1	992,77 m ³
Boring 2	991,80 m ³
TOTAL UDPUMPET	1943,58 m ³
Udpumpning	1943,58 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG



ELFORBRUG	
Samlet proces	2104 kWh
Delproces / udpumpning	848 kWh



NATFORBRUG



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER	
1	131 timer
2	127 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	259 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport November 2020

Faurbo Vandværk

2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,13 m	-53,20 m	4,07 m	992,77 m ³
2	-49,38 m	-53,68 m	4,30 m	991,80 m ³



Blue Control®
BC7000