

# DRIFTSRAPPORT

Månedssrapport Juni 2023

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2849,25 m <sup>3</sup>
Boring 1	1422,75 m <sup>3</sup>
Boring 2	1426,50 m <sup>3</sup>
TOTAL UDPUMPET	2827,36 m <sup>3</sup>
Udpumpning	2827,36 m <sup>3</sup>
TOTAL SKYLLEVAND	9,06 m <sup>3</sup>
Skyllevand	9,06 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	2612 kWh
Delproces / udpumpning	937 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	7 skyl
Filter 2	7 skyl
Filter 3	9 skyl
Filter 4	9 skyl

## DRIFTTIMER



BORINGER	
1	179 timer
2	178 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	357 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedssrapport Juni 2023

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,29 m	-53,66 m	4,37 m	1422,75 m <sup>3</sup>
2	-49,30 m	-53,63 m	4,33 m	1426,50 m <sup>3</sup>

Fordeling for indvundet vand



Blue Control®  
BC7000