




# Faurbo Vandværk

## Månedssrapport 09-2016



## Mængder

Udpumpet vandmængde:	Total: 2.280,3 m <sup>3</sup>	Måler 1: 2.280,3 m <sup>3</sup>
Indvundet vandmængde:	Total: 1.829,1 m <sup>3</sup>	Måler 2: 1.829,1 m <sup>3</sup>

## Forbrug

Elforbrug:	Total: 2.372,0 kWh	Udpumpet: 867,0 kWh
	Total: 1,04 kWh/m <sup>3</sup>	Udpumpet: 0,38 kWh/m <sup>3</sup>

## Flow

### Flow måler 1:

Min. Flow:	0,00 m <sup>3</sup> /h	Tidspunkt: 01-09-16 00:00:05
Max. Flow:	14,43 m <sup>3</sup> /h	Tidspunkt: 08-09-16 03:09:48

### Flow måler 2:

Min. Flow:	0,00 m <sup>3</sup> /h	Tidspunkt: 01-09-16 00:00:00
Max. Flow:	8,53 m <sup>3</sup> /h	Tidspunkt: 03-09-16 10:10:20

## Niveauer i boringer:

Boring 1 niveau:	Højest: -48,31 m	Lavest: -51,66 m	Sænkning: 3,35 m
Boring 2 niveau:	Højest: -48,87 m	Lavest: -53,30 m	Sænkning: 4,43 m

## Filter:

Filter 1:	Antal skyl: 6
Filter 2:	Antal skyl: 6

## Drifttimer:

	Periode:	Total:
Boring 1:	113 Timer	2313 Timer
Boring 2:	239 Timer	3940 Timer
Pumpe 1:	357 Timer	9186 Timer
Pumpe 2:	357 Timer	9185 Timer