

# DRIFTSRAPPORT

Månedssrapport August 2021

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2493,67 m <sup>3</sup>
Boring 1	1236,31 m <sup>3</sup>
Boring 2	1257,36 m <sup>3</sup>
TOTAL UDPUMPET	2460,02 m <sup>3</sup>
Udpumpning	2460,02 m <sup>3</sup>
TOTAL SKYLLEVAND	0,00 m <sup>3</sup>
Skyllevand	0,00 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	2505 kWh
Delproces / udpumpning	956 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	6 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

## DRIFTTIMER



BORINGER	
1	170 timer
2	168 timer
PUMPER	
1	364 timer
2	380 timer
FILTERMOTOR	
1	338 timer
2	1 timer



Blue Control®  
BC7000



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,22 m	-53,29 m	4,07 m	1236,31 m <sup>3</sup>
2	-49,68 m	-53,67 m	4,00 m	1257,36 m <sup>3</sup>

Fordeling for indvundet vand

