

DRIFTSRAPPORT

Månedsrapport Juli 2023

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2430,83 m ³
Boring 1	1226,47 m ³
Boring 2	1204,36 m ³
TOTAL UDPUMPET	2405,76 m ³
Udpumpning	2405,76 m ³
TOTAL SKYLLEVAND	6,40 m ³
Skyllevand	6,40 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2289 kWh
Delproces / udpumpning	870 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	9 skyl
Filter 4	9 skyl

DRIFTTIMER



BORINGER	
1	154 timer
2	150 timer
PUMPER	
1	364 timer
2	379 timer
FILTERMOTOR	
1	304 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedrapport Juli 2023

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,35 m	-53,67 m	4,32 m	1226,47 m ³
2	-49,34 m	-53,63 m	4,28 m	1204,36 m ³

Fordeling for indvundet vand



Blue Control®
BC7000