

DRIFTSRAPPORT

Månedssrapport Juni 2021

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2665,21 m ³
Boring 1	1314,37 m ³
Boring 2	1350,84 m ³
TOTAL UDPUMPET	2632,52 m ³
Udpumpning	2632,52 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2686 kWh
Delproces / udpumpning	968 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	6 skyl
Filter 2	7 skyl
Filter 3	9 skyl
Filter 4	9 skyl

DRIFTTIMER



BORINGER	
1	188 timer
2	187 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	374 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport Juni 2021

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,01 m	-52,98 m	3,97 m	1314,37 m ³
2	-49,25 m	-53,33 m	4,08 m	1350,84 m ³

Fordeling for indvundet vand



Blue Control®
BC7000