


Faurbo Vandværk

Månedsrapport 08-2017



Mængder

| | | | | |
|-----------------------|--------|------------------------|----------|------------------------|
| Udpumpet vandmængde: | Total: | 2.065,3 m ³ | Måler 1: | 2.065,3 m ³ |
| Indvundet vandmængde: | Total: | 2.094,0 m ³ | Måler 2: | 2.094,0 m ³ |

Forbrug

| | | | | |
|------------|--------|-------------------------|-----------|-------------------------|
| Elforbrug: | Total: | 2.224,5 kWh | Udpumpet: | 856,4 kWh |
| | Total: | 1,08 kWh/m ³ | Udpumpet: | 0,41 kWh/m ³ |

Flow

Flow måler 1:

| | | |
|------------|-------------------------|------------------------------|
| Min. Flow: | 0,00 m ³ /h | Tidspunkt: 01-08-17 00:01:13 |
| Max. Flow: | 13,68 m ³ /h | Tidspunkt: 04-08-17 03:09:37 |

Flow måler 2:

| | | |
|------------|-------------------------|------------------------------|
| Min. Flow: | 0,00 m ³ /h | Tidspunkt: 01-08-17 00:00:00 |
| Max. Flow: | 17,26 m ³ /h | Tidspunkt: 03-08-17 16:22:33 |

Niveauer i boringer:

| | | | | | | |
|------------------|---------|----------|---------|----------|-----------|--------|
| Boring 1 niveau: | Højest: | -48,61 m | Lavest: | -52,75 m | Sænkning: | 4,14 m |
| Boring 2 niveau: | Højest: | -49,17 m | Lavest: | -54,14 m | Sænkning: | 4,97 m |

Filter:

| | | |
|-----------|-------------|----|
| Filter 1: | Antal skyl: | 5 |
| Filter 2: | Antal skyl: | 5 |
| Filter 3: | Antal skyl: | 11 |
| Filter 4: | Antal skyl: | 11 |

Drifttimer:

| | Periode: | Total: |
|-----------|-----------|-------------|
| Boring 1: | 103 Timer | 3519 Timer |
| Boring 2: | 156 Timer | 6152 Timer |
| Pumpe 1: | 356 Timer | 13103 Timer |
| Pumpe 2: | 373 Timer | 13112 Timer |