

DRIFTSRAPPORT

Årsrapport 2022

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	24922,89 m ³
Boring 1	12431,97 m ³
Boring 2	12490,92 m ³
TOTAL UDPUMPET	24542,21 m ³
Udpumpning	24542,21 m ³
TOTAL SKYLLEVAND	73,98 m ³
Skyllevand	73,98 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	25980 kWh
Delproces / udpumpning	9950 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	60 skyl
Filter 2	59 skyl
Filter 3	85 skyl
Filter 4	85 skyl

DRIFTTIMER



BORINGER	
1	1591 timer
2	1578 timer
PUMPER	
1	4447 timer
2	4312 timer
FILTERMOTOR	
1	3162 timer
2	8 timer



Blue Control®
BC7000



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,66 m	-54,37 m	5,72 m	12431,97 m ³
2	-49,03 m	-53,94 m	4,91 m	12490,92 m ³

Fordeling for indvundet vand

