

DRIFTSRAPPORT

Månedssrapport Januar 2024

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2556,99 m ³
Boring 1	1282,51 m ³
Boring 2	1274,48 m ³
TOTAL UDPUMPET	2537,94 m ³
Udpumpning	2537,94 m ³
TOTAL SKYLLEVAND	7,52 m ³
Skyllevand	7,52 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2719 kWh
Delproces / udpumpning	911 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	6 skyl
Filter 2	6 skyl
Filter 3	9 skyl
Filter 4	9 skyl

DRIFTTIMER



BORINGER	
1	166 timer
2	165 timer
PUMPER	
1	364 timer
2	380 timer
FILTERMOTOR	
1	329 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport Januar 2024

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,76 m	-52,87 m	4,12 m	1282,51 m ³
2	-48,70 m	-53,00 m	4,30 m	1274,48 m ³

Fordeling for indvundet vand



Blue Control®
BC7000