

DRIFTSRAPPORT

Månedsrapport Marts 2022

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	1939,46 m ³
Boring 1	963,20 m ³
Boring 2	976,26 m ³
TOTAL UDPUMPET	1907,35 m ³
Udpumpning	1907,35 m ³
TOTAL SKYLLEVAND	5,33 m ³
Skyllevand	5,33 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2369 kWh
Delproces / udpumpning	858 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER	
1	149 timer
2	147 timer
PUMPER	
1	376 timer
2	367 timer
FILTERMOTOR	
1	294 timer
2	1 timer



Blue Control®
BC7000



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,89 m	-52,34 m	3,45 m	963,20 m ³
2	-49,12 m	-52,70 m	3,58 m	976,26 m ³

Fordeling for indvundet vand

