

DRIFTSRAPPORT

Månedsrapport Juli 2021

Faurbo Vandværk

1/2



MÆNGDER

| | |
|------------------|------------------------|
| TOTAL INDVUNDET | 2662,54 m ³ |
| Boring 1 | 1330,51 m ³ |
| Boring 2 | 1332,03 m ³ |
| TOTAL UDPUMPET | 2621,82 m ³ |
| Udpumpning | 2621,82 m ³ |
| TOTAL SKYLLEVAND | 0,00 m ³ |
| Skyllevand | 0,00 m ³ |

ELFORBRUG




| | |
|------------------------|----------|
| ELFORBRUG | |
| Samlet proces | 2748 kWh |
| Delproces / udpumpning | 980 kWh |



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

| | |
|----------|--------|
| Filter 1 | 6 skyl |
| Filter 2 | 6 skyl |
| Filter 3 | 9 skyl |
| Filter 4 | 9 skyl |

DRIFTTIMER



| | |
|-------------|-----------|
| BORINGER | |
| 1 | 183 timer |
| 2 | 177 timer |
| PUMPER | |
| 1 | 368 timer |
| 2 | 376 timer |
| FILTERMOTOR | |
| 1 | 360 timer |
| 2 | 1 timer |



Blue Control®
BC7000



NIVEAUER I BORINGER

| BORING | HØJEST | LAVEST | SÆNKNING | MÆNGDE |
|--------|----------|----------|----------|------------------------|
| 1 | -49,22 m | -53,17 m | 3,95 m | 1330,51 m ³ |
| 2 | -49,60 m | -53,55 m | 3,95 m | 1332,03 m ³ |

Fordeling for indvundet vand

