

# DRIFTSRAPPORT

Månedsrapport September 2021

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2235,17 m <sup>3</sup>
Boring 1	1114,34 m <sup>3</sup>
Boring 2	1120,83 m <sup>3</sup>
TOTAL UDPUMPET	2205,02 m <sup>3</sup>
Udpumpning	2205,02 m <sup>3</sup>
TOTAL SKYLLEVAND	0,00 m <sup>3</sup>
Skyllevand	0,00 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	2307 kWh
Delproces / udpumpning	893 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

## DRIFTTIMER



BORINGER	
1	155 timer
2	150 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	305 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedsrapport September 2021

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,39 m	-53,21 m	3,82 m	1114,34 m <sup>3</sup>
2	-49,72 m	-53,73 m	4,01 m	1120,83 m <sup>3</sup>

Fordeling for indvundet vand



Blue Control®  
BC7000