

# DRIFTSRAPPORT

Månedsrapport April 2020

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2178,03 m <sup>3</sup>
Boring 1	1019,11 m <sup>3</sup>
Boring 2	1158,92 m <sup>3</sup>
TOTAL UDPUMPET	2147,15 m <sup>3</sup>
Udpumpning	2147,15 m <sup>3</sup>
TOTAL SKYLLEVAND	0,00 m <sup>3</sup>
Skyllevand	0,00 m <sup>3</sup>

## ELFORBRUG




### ELFORBRUG

Samlet proces	2216 kWh
Delproces / udpumpning	880 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

## DRIFTTIMER



### BORINGER

1	127 timer
2	145 timer

### PUMPER

1	360 timer
2	360 timer

### FILTERMOTOR

1	272 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedsrapport April 2020

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-47,87 m	-52,75 m	4,87 m	1019,11 m <sup>3</sup>
2	-48,62 m	-53,05 m	4,42 m	1158,92 m <sup>3</sup>

Fordeling for indvundet vand



● Boring 1 : 46.8%  
● Boring 2 : 53.2%



Blue Control®  
BC7000