

# DRIFTSRAPPORT

Månedsrapport September 2020

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2291,37 m <sup>3</sup>
Boring 1	1138,02 m <sup>3</sup>
Boring 2	1153,35 m <sup>3</sup>
TOTAL UDPUMPET	2258,44 m <sup>3</sup>
Udpumpning	2258,44 m <sup>3</sup>
TOTAL SKYLLEVAND	0,00 m <sup>3</sup>
Skyllevand	0,00 m <sup>3</sup>

## ELFORBRUG



ELFORBRUG	
Samlet proces	2437 kWh
Delproces / udpumpning	901 kWh



## NATFORBRUG



## FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	7 skyl
Filter 4	7 skyl

## DRIFTTIMER



BORINGER	
1	146 timer
2	144 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	290 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedsrapport September 2020

Faurbo Vandværk

2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,15 m	-53,36 m	4,21 m	1138,02 m <sup>3</sup>
2	-49,40 m	-53,78 m	4,38 m	1153,35 m <sup>3</sup>



Blue Control®  
BC7000