

DRIFTSRAPPORT

Månedsrapport December 2021

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	1952,89 m ³
Boring 1	978,90 m ³
Boring 2	973,99 m ³
TOTAL UDPUMPET	1925,16 m ³
Udpumpning	1925,16 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2298 kWh
Delproces / udpumpning	871 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	4 skyl
Filter 2	4 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER	
1	142 timer
2	137 timer
PUMPER	
1	364 timer
2	380 timer
FILTERMOTOR	
1	280 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport December 2021

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,18 m	-52,88 m	3,70 m	978,90 m ³
2	-49,40 m	-53,30 m	3,90 m	973,99 m ³

Fordeling for indvundet vand



● Boring 1 : 50.1%
● Boring 2 : 49.9%



Blue Control®
BC7000