

DRIFTSRAPPORT

Månedssrapport Oktober 2019

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2018,03 m ³
Boring 1	1064,38 m ³
Boring 2	953,65 m ³
TOTAL UDPUMPET	2006,99 m ³
Udpumpning	2006,99 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2385 kWh
Delproces / udpumpning	869 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	4 skyl
Filter 2	4 skyl
Filter 3	8 skyl
Filter 4	8 skyl

DRIFTTIMER



BORINGER	
1	123 timer
2	150 timer
PUMPER	
1	380 timer
2	365 timer
FILTERMOTOR	
1	273 timer
2	1 timer

DRIFTSRAPPORT

Månedsrapport Oktober 2019

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,21 m	-53,92 m	4,72 m	1064,38 m ³
2	-49,54 m	-53,24 m	3,69 m	953,65 m ³

Fordeling for indvundet vand



Blue Control®
BC7000