


Faurbo Vandværk

Månedsrapport 12-2017



Mængder

Udpumpet vandmængde:	Total:	1.565,2 m ³	Måler 1:	1.565,2 m ³
Indvundet vandmængde:	Total:	1.601,8 m ³	Måler 2:	1.601,8 m ³

Forbrug

Elforbrug:	Total:	1.616,2 kWh	Udpumpet:	710,6 kWh
	Total:	1,03 kWh/m ³	Udpumpet:	0,45 kWh/m ³

Flow

Flow måler 1:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 01-12-17 00:05:40
Max. Flow:	13,72 m ³ /h	Tidspunkt: 07-12-17 03:09:40

Flow måler 2:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 01-12-17 00:00:00
Max. Flow:	13,45 m ³ /h	Tidspunkt: 02-12-17 19:33:47

Niveauer i boringer:

Boring 1 niveau:	Højest:	-48,11 m	Lavest:	-52,43 m	Sænkning:	4,32 m
Boring 2 niveau:	Højest:	-48,68 m	Lavest:	-53,70 m	Sænkning:	5,01 m

Filter:

Filter 1:	Antal skyl:	4
Filter 2:	Antal skyl:	4
Filter 3:	Antal skyl:	9
Filter 4:	Antal skyl:	9

Drifttimer:

	Periode:	Total:
Boring 1:	82 Timer	3902 Timer
Boring 2:	118 Timer	6703 Timer
Pumpe 1:	323 Timer	14479 Timer
Pumpe 2:	305 Timer	14478 Timer