

# DRIFTSRAPPORT

Månedsrapport Maj 2021

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2420,30 m <sup>3</sup>
Boring 1	1215,23 m <sup>3</sup>
Boring 2	1205,07 m <sup>3</sup>
TOTAL UDPUMPET	2391,52 m <sup>3</sup>
Udpumpning	2391,52 m <sup>3</sup>
TOTAL SKYLLEVAND	0,00 m <sup>3</sup>
Skyllevand	0,00 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	2456 kWh
Delproces / udpumpning	946 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	6 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

## DRIFTTIMER



BORINGER	
1	172 timer
2	166 timer
PUMPER	
1	380 timer
2	364 timer
FILTERMOTOR	
1	338 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedsrapport Maj 2021

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,69 m	-52,71 m	4,03 m	1215,23 m <sup>3</sup>
2	-48,93 m	-53,02 m	4,09 m	1205,07 m <sup>3</sup>

Fordeling for indvundet vand



Blue Control®  
BC7000