

DRIFTSRAPPORT

Årsrapport 2019

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	25772,10 m ³
Boring 1	14361,61 m ³
Boring 2	11410,49 m ³
TOTAL UDPUMPET	25251,90 m ³
Udpumpning	25251,90 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	29812 kWh
Delproces / udpumpning	10490 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	62 skyl
Filter 2	62 skyl
Filter 3	89 skyl
Filter 4	89 skyl

DRIFTTIMER



BORINGER	
1	1627 timer
2	1821 timer
PUMPER	
1	4356 timer
2	4405 timer
FILTERMOTOR	
1	3442 timer
2	8 timer




Blue Control®
BC7000



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,80 m	-54,06 m	5,27 m	14361,61 m ³
2	-49,01 m	-53,79 m	4,78 m	11410,49 m ³

Fordeling for indvundet vand



● Boring 1 : 55.7%
● Boring 2 : 44.3%

