

# DRIFTSRAPPORT

Månedsrapport April 2024

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2207,52 m <sup>3</sup>
Boring 1	1102,76 m <sup>3</sup>
Boring 2	1104,76 m <sup>3</sup>
TOTAL UDPUMPET	2186,67 m <sup>3</sup>
Udpumpning	2186,67 m <sup>3</sup>
TOTAL SKYLLEVAND	0,10 m <sup>3</sup>
Skyllevand	0,10 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	2485 kWh
Delproces / udpumpning	823 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

## DRIFTTIMER



BORINGER	
1	169 timer
2	168 timer
PUMPER	
1	374 timer
2	345 timer
FILTERMOTOR	
1	337 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedssrapport April 2024

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,13 m	-52,23 m	4,10 m	1102,76 m <sup>3</sup>
2	-48,46 m	-52,34 m	3,87 m	1104,76 m <sup>3</sup>

Fordeling for indvundet vand



- Boring 1 : 50.0%
- Boring 2 : 50.0%



Blue Control®  
BC7000