

DRIFTSRAPPORT

Månedsrapport Oktober 2021

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2156,45 m ³
Boring 1	1071,28 m ³
Boring 2	1085,17 m ³
TOTAL UDPUMPET	2124,60 m ³
Udpumpning	2124,60 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2302 kWh
Delproces / udpumpning	901 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER	
1	150 timer
2	148 timer
PUMPER	
1	380 timer
2	365 timer
FILTERMOTOR	
1	298 timer
2	1 timer



Blue Control®
BC7000



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,31 m	-53,20 m	3,90 m	1071,28 m ³
2	-49,58 m	-53,67 m	4,09 m	1085,17 m ³

Fordeling for indvundet vand

