

DRIFTSRAPPORT

Månedssrapport Marts 2019

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	1977,63 m ³
Boring 1	1061,43 m ³
Boring 2	916,20 m ³
TOTAL UDPUMPET	1930,79 m ³
Udpumpning	1930,79 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2377 kWh
Delproces / udpumpning	853 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER	
1	118 timer
2	137 timer
PUMPER	
1	380 timer
2	363 timer
FILTERMOTOR	
1	255 timer
2	1 timer

DRIFTSRAPPORT

Månedsrapport Marts 2019

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,94 m	-53,94 m	5,00 m	1061,43 m ³
2	-49,17 m	-53,07 m	3,90 m	916,20 m ³

Fordeling for indvundet vand



● Boring 1 : 53.7%
● Boring 2 : 46.3%



Blue Control®
BC7000