

# DRIFTSRAPPORT

Månedsrapport August 2023

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2442,49 m <sup>3</sup>
Boring 1	1225,02 m <sup>3</sup>
Boring 2	1217,47 m <sup>3</sup>
TOTAL UDPUMPET	2414,70 m <sup>3</sup>
Udpumpning	2414,70 m <sup>3</sup>
TOTAL SKYLLEVAND	7,64 m <sup>3</sup>
Skyllevand	7,64 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	2610 kWh
Delproces / udpumpning	876 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	6 skyl
Filter 2	6 skyl
Filter 3	9 skyl
Filter 4	9 skyl

## DRIFTTIMER



BORINGER	
1	155 timer
2	153 timer
PUMPER	
1	380 timer
2	364 timer
FILTERMOTOR	
1	307 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedssrapport August 2023

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,29 m	-53,56 m	4,27 m	1225,02 m <sup>3</sup>
2	-49,31 m	-53,65 m	4,34 m	1217,47 m <sup>3</sup>

Fordeling for indvundet vand



● Boring 1 : 50.2%  
● Boring 2 : 49.8%



Blue Control®  
BC7000