

DRIFTSRAPPORT

Årsrapport 2021

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	26571,00 m ³
Boring 1	13213,02 m ³
Boring 2	13357,98 m ³
TOTAL UDPUMPET	26175,46 m ³
Udpumpning	26175,46 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	28206 kWh
Delproces / udpumpning	10786 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	61 skyl
Filter 2	60 skyl
Filter 3	91 skyl
Filter 4	91 skyl

DRIFTTIMER



BORINGER	
1	1848 timer
2	1813 timer
PUMPER	
1	4376 timer
2	4384 timer
FILTERMOTOR	
1	3660 timer
2	8 timer



Blue Control®
BC7000



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,61 m	-53,52 m	4,91 m	13213,02 m ³
2	-48,87 m	-53,73 m	4,86 m	13357,98 m ³

Fordeling for indvundet vand

