

# DRIFTSRAPPORT

Månedsrapport Maj 2020

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2562,23 m <sup>3</sup>
Boring 1	1254,29 m <sup>3</sup>
Boring 2	1307,94 m <sup>3</sup>
TOTAL UDPUMPET	2529,47 m <sup>3</sup>
Udpumpning	2529,47 m <sup>3</sup>
TOTAL SKYLLEVAND	0,00 m <sup>3</sup>
Skyllevand	0,00 m <sup>3</sup>

## ELFORBRUG



ELFORBRUG	
Samlet proces	2574 kWh
Delproces / udpumpning	970 kWh



## NATFORBRUG



## FILTRE

Filter 1	6 skyl
Filter 2	6 skyl
Filter 3	8 skyl
Filter 4	8 skyl

## DRIFTTIMER



BORINGER	
1	164 timer
2	165 timer
PUMPER	
1	364 timer
2	380 timer
FILTERMOTOR	
1	327 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedsrapport Maj 2020

Faurbo Vandværk

2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-47,95 m	-52,16 m	4,21 m	1254,29 m <sup>3</sup>
2	-48,75 m	-53,20 m	4,45 m	1307,94 m <sup>3</sup>



Blue Control®  
BC7000