

DRIFTSRAPPORT

Månedsrapport Maj 2023

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2994,44 m ³
Boring 1	1506,81 m ³
Boring 2	1487,63 m ³
TOTAL UDPUMPET	2964,25 m ³
Udpumpning	2964,25 m ³
TOTAL SKYLLEVAND	9,26 m ³
Skyllevand	9,26 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2680 kWh
Delproces / udpumpning	981 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	7 skyl
Filter 2	7 skyl
Filter 3	10 skyl
Filter 4	10 skyl

DRIFTTIMER



BORINGER	
1	188 timer
2	184 timer
PUMPER	
1	380 timer
2	364 timer
FILTERMOTOR	
1	372 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Maj 2023

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,04 m	-53,34 m	4,30 m	1506,81 m ³
2	-48,92 m	-53,45 m	4,52 m	1487,63 m ³

Fordeling for indvundet vand



Blue Control®
BC7000