

DRIFTSRAPPORT

Månedsrapport Juni 2018

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2640,00 m ³
Indvinding	2640,00 m ³
TOTAL UDPUMPET	2566,80 m ³
Udpumpning	2566,80 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2601 kWh
Delproces / udpumpning	952 kWh



NATFORBRUG

Gennemsnitligt vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	6 skyl
Filter 2	6 skyl
Filter 3	13 skyl
Filter 4	13 skyl

DRIFTTIMER



BORINGER	
1	147 timer
2	175 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	322 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport Juni 2018

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,86 m	-53,74 m	4,89 m	2640,00 m ³
2	-49,12 m	-53,10 m	3,98 m	0,00 m ³

Fordeling for indvundet vand



● Indvinding : 100.0%



Blue Control®
BC7000